

ASBESTOS REGISTER

SITE: 7794 Lummis 33 Murdoch Street, Ermington

LAST UPDATED: 24/04/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
21/04/2017	External cladding under metal cladding	Asbestos cement sheet	Non-friable	80.5 sqm	Good/stable Painted	Remove and dispose of ACM as part of the contract works
21/04/2017	Eave soffit lining	Asbestos cement sheet under metal cladding	Non-friable	15 sqm	Good/stable Painted	Remove and dispose of ACM as part of the contract works
21/04/2017	Bathroom wall lining	Asbestos cement sheet	Non-friable	14.5 sqm	Good/stable Painted	Protect and retain ACM from damage during the course of the works
21/04/2017	Disused ceiling mounted HWS	ACM	Non-friable	Unknown	Unknown	Remove and dispose of ACM as part of the contract works
21/04/2017	Electrical meter board	ACM rear lining	Non-friable	0.25 sqm	Good/stable	Remove and dispose of ACM as part of the contract works