

# ASBESTOS REGISTER

**SITE:** 7728      Blaikie      93 Davidson Avenue, Concord

**LAST UPDATED:** 28/04/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
12/05/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
12/05/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works