

ASBESTOS REGISTER

SITE: 7766 Warburton 40 Rangers Avenue, Mosman

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
11/11/2016	Under floor space	Malthoid sarking	Non-friable	Unknown	Good/stable	Remove and dispose of the ACM as part of the contract works
11/11/2016	Cladding (rear extension)	Asbestos cement sheet	Non-friable	10 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
11/11/2016	Gable end lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM form damage during the course of the works
11/11/2016	Lobby	Asbestos cement sheet	Non-friable	3 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
11/11/2016	Laundry	Asbestos cement sheet	Non-friable	2.25 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
11/11/2016	Storage	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM form damage during the course of the works