

ASBESTOS REGISTER

SITE: 7710 Whitehead.Robson 112 West Street, Crows Nest

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
02/03/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works