

ASBESTOS REGISTER

SITE: 7790 Thompson 12 Pardey Street, Kingsford

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
15/11/2016	Exterior cladding	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
15/11/2016	Gable end lining	Asbestos cement sheet	Non-friable	4sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
15/11/2016	WC	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
15/11/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
15/11/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works