

# ASBESTOS REGISTER

**SITE:** 7785 People 40 Kulgoa Avenue, Ryde

**LAST UPDATED:** 28/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/11/2016	Cladding	Asbestos cement sheet cladding	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Rear verandah	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Bathroom (skylight)	Asbestos cement sheet	Non-friable	2 sqm	Good/stable	Remove and dispose of the ACm as part of the contract works

## ASBESTOS REGISTER

18/11/2016	Kitchen (splay ceiling)	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Laundry (splay ceiling)	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Shower (splay ceiling)	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
18/11/2016	Garage	Asbestos cement sheet roofing and cladding	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works