

# ASBESTOS REGISTER

**SITE:** 7769 Percy 22 Nareen Parade, North Narrabeen

**LAST UPDATED:** 13/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
03/02/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	7.5sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
03/02/2017	Balcony soffit lining	Asbestos cement sheet	Non-friable	24sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
03/02/2017	Balcony privacy walls	Asbestos cement sheet	Non-friable	9.6sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
03/02/2017	Ground floor shower wall opposite existing toilet (location of original washing machine)	Asbestos cement sheet	Non-friable	2.5sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works