

ASBESTOS REGISTER

SITE: 7812 Burden 5A Darling Street, Bronte

LAST UPDATED: 09/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
08/03/2017	Eave soffit lining (rear balcony)	Asbestos cement sheet	Non-friable	2 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
08/03/2017	Gable end cladding	Asbestos cement sheet	Non-friable	6 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
08/03/2017	Balcony privacy wall and window surround	Asbestos cement sheet	Non-friable	3 sqm	Good/stable Painted	Remove the ACM as part of the contract works
08/03/2017	Laundry and WC wall lining (lower ground floor)	Asbestos cement sheet	Non-friable	8.6 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works