

ASBESTOS REGISTER

SITE: 7869 Irvine.Brooks 72 Middle Street, Kingsford

LAST UPDATED: 22/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
15/09/2017	Gable end cladding	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
15/09/2017	Front porch eave soffit lining	Asbestos cement sheet	Non-friable	1 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
15/09/2017	Laundry wall lining	Asbestos cement sheet	Non-friable	2 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works