

ASBESTOS REGISTER

SITE: 7832 Strano 23 Colwell Crescent, Chatswood

LAST UPDATED: 19/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
14/06/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	16 sqm	Good/Stable Surface coated to the exposed areas	9 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
14/06/2017	Porch soffit lining	Asbestos cement sheet	Non-friable	6.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
14/06/2017	Laundry ceiling lining	Asbestos cement sheet	Non-friable	4 sqm	Good/Stable Surface coated to the exposed areas	Remove and dispose of the ACM as part of the contract works
14/06/2017	Storage room ceiling lining	Asbestos cement sheet	Non-friable	12 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage as part of the contract works
14/06/2017	Disused ceiling mounted hot water system	ACM	Non-friable	Unknown	Unknown	Remove and dispose of the disused hot water system

ASBESTOS REGISTER

14/06/2017	Garage ceiling lining	Asbestos cement sheet	Non-friable	16.5 sqm	Good/Stable Surface coated to the exposed areas	Remove and dispose of the ACM as part of the contract works
14/06/2017	Garage roof	ACM in bitumen based roofing	Non-friable	16.5 sqm	Good/Stable	Remove and dispose of the ACM as part of the contract works
14/06/2017	Under floor space	Asbestos cement sheet	Non-friable	Unknown	Broken pieces Damaged	Remove and dispose of the ACM as part of the contract works