

ASBESTOS REGISTER

SITE: 7719 Sutanto.Hendarto 269 Botany Street, Kingsford

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

| Date Identified | Location of ACM | Type | Friable / Non-Friable | Quantity | Condition | Assessment / Action |
|-----------------|------------------------|-----------------------|-----------------------|----------|-------------|---|
| 09/06/2016 | Eave soffit lining | Asbestos cement sheet | Non-friable | 14 sqm | Good/stable | Remove and dispose of the ACM as part of the contract works |
| 09/06/2016 | Electrical meter board | Asbestos cement sheet | Non-friable | Unknown | Good/stable | Protect the retained ACM from damage during the course of the works |