

ASBESTOS REGISTER

SITE: 7800 Passicot 73 Clovelly Road, Randwick

LAST UPDATED: 28/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
20/01/2017	Laundry wall lining (internal)	Asbestos cement sheet	Non-friable	9.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
20/01/2017	Laundry wall lining (external)	Asbestos cement sheet	Non-friable	7 sqm	Broken behind barbecue Painted	Removed the damaged ACM as part of the contract works