

3. DO NOT PLACE CONDUITS, PIPES, ETC. IN CONCRETE COVER
4. REINFORCEMENT SYMBOLS :
N – DENOTES DEFORMED D500N BARS TO AS/NZS 4671
R – DENOTES PLAIN 230R GRADE BARS TO AS 1302
SL– DENOTES DEFORMED SQUARE D500SL GRADE MESH TO AS/NZS 4671
TM– DENOTES HARD DRAWN TRENCH MESH TO AS 1304
5. CONCRETE IN SLABS TO BE MECHANICALLY VIBRATED DURING PLACING.
6. CURE CONCRETE BY KEEPING CONSTANTLY DAMP FOR AT LEAST 5 DAYS AFTER PLACING.
7. REINFORCEMENT TO BE SUPPORTED ON BAR CHAIRS SPACED AT EVERY 5TH WIRE IN BOTH DIRECTIONS.
8. GRADE FINISHED GROUND SURFACE TO DIVERT WATER AWAY FROM SLAB ON ALL SIDES AND TO PREVENT PONDING.
9. TERMITE PROTECTION TO BE IN ACCORDANCE WITH A.S.3660.1–1995 AND COUNCIL'S REQUIREMENTS