

ASBESTOS REGISTER

SITE: 7810 Trinca 44 Sackville Street, Maroubra

LAST UPDATED: 21/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
15/12/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	18.5 sqm	Good/stable Painted	3.6 sqm to be removed as part of the contract works. Protect the retained ACM from damage during the course of the works
15/12/2016	Garage ceiling lining	Asbestos cement sheet	Non-friable	9.9 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
15/12/2016	Shed	Asbestos cement sheet cladding	Non-friable	9 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works