

# ASBESTOS REGISTER

**SITE:** 7632 Moloney 12 Brown Street, Bronte

**LAST UPDATED:** 28/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
02/09/2015	Exterior cladding	Asbestos cement sheet	Non-friable	2 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works