

# ASBESTOS REGISTER

**SITE:** 7753 Durning 360 Avoca Street, Kingsford

**LAST UPDATED:** 22/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/08/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	1.6 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
18/08/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/08/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/08/2016	BBQ area	Asbestos cement sheet	Non-friable	6 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works