

# ASBESTOS REGISTER

**SITE:** 7831 Freund 88 Dover Road, Rose Bay

**LAST UPDATED:** 20/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/10/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	9 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
18/10/2017	Gable end cladding	Asbestos cement sheet	Non-friable	6 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works