

ASBESTOS REGISTER

SITE: 7756 Salt 14 Marne Street, Vaucluse

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
25/01/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	33.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works