

ASBESTOS REGISTER

SITE: 7847 Moore.Harraghy 4 Barrett Place, Randwick

LAST UPDATED: 16/11/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
14/11/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
14/11/2017	Bathroom wall lining	Asbestos cement sheet	Non-friable	2.5 sqm	Goo/Stable	Protect the retained ACM from damage during the course of the works