

ASBESTOS REGISTER

SITE: 7825 Swinburn 62 Carrington Road, Randwick

LAST UPDATED: 29/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
24/05/2017	Gable end infill cladding	Asbestos cement sheet	Non-friable	1.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works