

ASBESTOS REGISTER

SITE: 7739 O'Neil 15 Greenfield Avenue, Middle Cove

LAST UPDATED: 15/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
22/07/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	7.7 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works 12 sqm removed on 12/05/2017
22/07/2016	Pitched roof cavity	Malthoid sarking	Non-friable	45 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works