

SITE SPECIFIC Risk Assessment

| Date: New ✓ Revised Page |
|----------------------------------|
|----------------------------------|

TRADE: SCAFFOLDER - DISMANTLE

| Job No: | 7603/14 | Client: | BOLAND |
|----------|--------------------------------------|-------------|---------------|
| Address: | 20 Everett Street, Maroubra NSW 2035 | Supervisor: | DEAN BERINGER |

| "1" action now "2" action ASAP "3" actio | n ASAP |
|--|--------|
|--|--------|

Note 1: Refer to the general Safety Plan and Safe Work Method Statement.

Note 2: All scaffolding to comply with AS/NZS 1576.1-1995 and WorkCover NSW industry standard – *erecting, altering and dismantling scaffolding - Part 1*

Note 3: all *manual tasks* to comply with the requirements of Safe Work Australia – National Code of Practice for Manual Handling 2009 and /or WorkCover NSW Code of Practice - Hazardous manual tasks

Note 4: Review of Control Measures - If there are any tasks that may be included by way of variation to the plans or an alternative approach to the set task, it is a requirement to carry out a "specific Risk Assessment" for the task or tasks.

| | | Lil | keliho | od | | Result | | | | | |
|--|---|--------|----------|----------|-------|--------|-------|----------|---|---------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| Access to site / work areas - Slips, trips, falls and accessibility - Access ways not clearly defined | Slips, trips and falls | | ✓ | | | ✓ | | 3 | Assess travel path and distance to work area Ensure unobstructed access to site and work areas. | Site Supervisor / all 'workers' | |
| Stored materials - Slips, trips, falls and accessibility - Access ways not clearly defined | Slips, trips and falls | | √ | | | ✓ | | 2 | Assess travel path and distance to work area Ensure unobstructed access to work areas. Provide and maintain barricades to isolate scaffold components and to restrict access. Provide designated storage areas | Site Supervisor / all 'workers' | |
| Manual tasks | Muscle strain - back injuries and cuts Over exertion or repetitive movements | | ✓ | | | ✓ | | 2 | Identify the risks and plan the tasks in consultation with the 'workers' Use trained 'workers' and team lifting. Rotate 'workers' and vary tasks | Contractor / all 'workers' | |

| | | Lil | keliho | od | Result | | | | | | |
|--|---|--------|-------------|----------|--------|----------|-------|----------|---|--|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| Exposure to noise Plant / equipment | Hearing damage | | ✓ | | | ✓ | | 2 | Isolate plant and equipment. Use appropriate PPE | All 'workers' | |
| Exposure to dust- Hazardous chemicals - Biological - | Dust inhalation - respiratory problems Skin and eye allergies/ irritations. | | ✓ | | | ✓ | | 2 | Appropriate procedures to contain dust. Use appropriate PPE - disposable dust protection. | Contractor / all 'workers' | |
| Exposure to UV light / weather - UV light - glare Extreme temperatures | Skin cancer / sun burn - Dehydration - heat stroke or fatigue Sight damage | | √ | | | ✓ | | 2 | Reduce exposure where possible. Monitor 'workers' condition Adequate fluid intake Use appropriate sun screen. Wear appropriate PPE. | Contractor / all 'workers' | |
| Contact with o/head electrical services / point of attachment - Power lines not isolated, covered or enclosed - Working to close to electrical supply - Strong winds causing power lines to swing close to work area - Wet conditions making 'tiger tails' ineffective | Electric shock or electrocution | | > | | | ✓ | | 3 | Identify that the electrical service is isolated prior to work commencing Provide 'tiger tails' [insulation] - adequately boxed adjacent to scaffold extended an appropriate distance past the boundary | Licensed Electrical Contractor or Approved person Site Supervisor Contractor / all 'workers' | |
| Dismantle scaffold - general - Slips, trips, falls and accessibility - Inadequate fall prevention system - Gravity - overbalancing / struck by falling objects - Manual tasks - Weather conditions | Slips, trips and falls from work platform Back injuries - muscle sprains and strains Fractures, bruises lacerations and personal injuries | | √ | | | ✓ | | 2 | Identify the risks and plan the tasks in consultation with the 'workers' Use trained and experienced 'workers' Rotate 'workers' and vary tasks Provide barricades to restrict access to around / under work areas. Set up a clear work area and maintain clear travel path. Dismantling of scaffold to be undertaken once shade | Contractor / all 'workers' | |

| | | Lil | keliho | od | I | Result | | | | | |
|--|---|--------|----------|----------|----------|--------|-------|----------|---|-------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| - rain and wind loading on scaffold Scaffold collapse - Proximity to other 'workers'. | | | | | | | | | cloth and mesh is removed. Ensure scaffold ties are only removed once shade cloth and mesh is removed and stripping has reached the level of the tie. Use appropriate PPE Use SWMS Identify the risks and plan the tasks in consultation with the | | |
| Dismantle scaffold - kickboards, handrails and deck Slips, trips, falls and accessibility - Inadequate fall prevention system - Gravity - overbalancing /struck by falling objects - Manual tasks — Weather conditions - rain and wind loading on scaffold Scaffold collapse - Proximity to other 'workers'. | Slips, trips and falls from work platform Back injuries - muscle sprains and strains Fractures, bruises lacerations and personal injuries | | ~ | | | ✓ | | 3 | Assess travel path and distance to work area Ensure unobstructed access to work areas. Use trained and experienced 'workers'. Rotate 'workers' and vary tasks Ensure 'workers' are harnessed to scaffold at all times when dismantling components. Ensure 'worker' only disconnects when working on two [2] planks and protected by handrail. Scaffolder 'worker' to work back towards scaffold access When access is disconnected dismantle next lift Use appropriate PPE | Contractor / all 'workers' | |
| Ladder access to work areas - Slips, trips, falls and accessibility - Inadequate work platform - Windy and or wet conditions - Gravity - | Fall from ladder Fractures, bruises lacerations and personal injuries | | √ | | √ | | | 3 | Identify the risks and plan the tasks in consultation with the 'workers' Use scaffold as working platform. Ensure ladder is at 4:1 slope. Secure ladder at base and top. Ensure 'workers' face the ladder when climbing up and down ladder. | Contractor / all 'workers' | |

| | | Lik | celiho | od | | Resu | lt | | | | |
|--|--|--------|----------|----------|-------|----------|-------|----------|---|-------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| overbalancing | | | | | | | | | Provide and maintain barricades to restrict access to work area. Limit the use of ladders | | |
| Site clean up on completion of work Manual tasks Exposure to dust - Hazardous chemicals Biological - | Exposure to dust - Hazardous chemicals - Biological – Personal injuries - cuts and abrasions. | | ✓ | | | √ | | 3 | Remove any temporary barricades if no longer required Place all associated building waste and rubbish in the designated waste area Leave site / work area in a clean and tidy condition | Contractor / all 'workers' | |

I / We have consulted with $Cape\ Cod\ Australia\ Pty$. Limited and have mutually agreed on the above procedures. This risk assessment provides details on how I / we will manage my / our work on this $Cape\ Cod\ Australia\ Pty$. Limited work site.

| Company Name: | Signed by: | Jaa Sprace |
|-------------------|-----------------------|---------------------------------|
| | for and on behalf of: | Cape Cod Australia Pty. Limited |
| Signed by: | | ABN: 54 000 605 407 |
| (Contractor PCBU) | | Builder's Licence No.: 5519 |
| ABN: | | |
| Address: | | |
| Phone: | | |
| Fax: | | |
| Email: | | |