

ASBESTOS REGISTER

SITE: 7781 Di Francesco.Hemmings 51 Eastern Avenue, Kingsford

LAST UPDATED: 22/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
02/09/2016	Exterior cladding	Asbestos cement cladding	Non-friable	2 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
02/09/2016	Gable end lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the contract works
02/09/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
02/09/2016	Rear patio	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
02/09/2016	Dining-skylight	Asbestos cement sheet	Non-friable	3 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
02/09/2016	Kitchen	Linoleum floor	Non-friable	Unknown	Good/stable	Remove and dispose of the ACM as part of the contract works

ASBESTOS REGISTER

02/09/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
02/09/2016	Carport	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
02/09/2016	Garage	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works