

ASBESTOS REGISTER

SITE: 7893 Guo 48 Gordon Street, Rosebery

LAST UPDATED: 15/12/2017

JOB NUMBER

CLIENT

ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
12/12/2017	Bathroom wall lining	Asbestos cement sheet	Non-friable	16.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
12/12/2017	Kitchen wall lining	Asbestos cement sheet	Non-friable	5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works