ASBESTOS REGISTER



SITE: 7806 Quinn 37 Varna Street, Clovelly LAST UPDATED: 10/07/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Туре	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/07/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	1.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
04/07/2017	Weatherboard cladding	Asbestos cement weatherboards	Non-friable	67.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Laundry wall/ceiling lining & spandrel panels	Asbestos cement sheet	Non-friable	8.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Laundry wall and ceiling linings	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Hallway and store room floor covering	ACM in linoleum base and adhesive	Non-friable	5.5 sqm	Good/Stable	To be removed by Cape Cod as part of the contract works

WHS-5.1-0502- Asbestos Register

Page 1 of 2

Issued: February 2017

Approved by: WHS & Human Resources Coordinator Printed: 10/07/2017 8:38 AM





04/07/2017	Study ceiling lining	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Dining room wall lining	Asbestos cement sheet	Non-friable	8.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Kitchen wall lining	Asbestos cement sheet	Non-friable	28.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
04/07/2017	Electrical meter board	ACM	Non-friable	0.25 sqm	Good/Stable	Protect the retained ACM from damage during the course of the works
04/07/2017	Small strip malthoid sarking to underside of roof tiles	ACM	Non-friable	1.5 sqm	Good/Stable	Remove and dispose of the ACM

Page 2 of 2

Issued: February 2017

Approved by: WHS & Human Resources Coordinator
Printed: 10/07/2017 8:38 AM