

ASBESTOS REGISTER

SITE: 7773 Flatters-Wright.Morris 9 Catherine Street, St Ives

LAST UPDATED: 10/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
25/10/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	2.25sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the proposed Contract works
25/10/2016	Gable end lining	Asbestos cement sheet	Non-friable	1sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the proposed Contract works
25/10/2016	Front porch	Asbestos cement sheet	Non-friable	2.5sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the proposed Contract works
25/10/2016	Ensuite – wall lining from the tiled floor to ceiling	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM wall lining from damage during the course of the works
25/10/2016	Bathroom – wall lining, tiled to 2.1m	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM wall lining from damage during the course of the works

ASBESTOS REGISTER

25/10/2016	Laundry – plasterboard ceiling lining with cove profiled cornice, tiled to 1m	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM wall lining from damage during the course of the works
25/10/2016	Shower – wall lining, tiled to 1.2m	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM wall lining from damage during the course of the works
25/10/2016	Electrical meter board	Asbestos cement	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works