

ASBESTOS REGISTER

SITE: 7818 Reid.Platt 2 Donovan Avenue, Maroubra

LAST UPDATED: 15/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
09/06/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Painted	6 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
09/06/2017	Garage roof sheeting	Asbestos cement sheet	Non-friable	21 sqm	Good/Stable Painted	To be removed by Cape Cod as part of the contract works
09/06/2017	Kitchen and dining floor covering	ACM in tile adhesive	Non-friable	3 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
09/06/2017	Bathroom ceiling lining	Asbestos cement sheet	Non-friable	6 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
09/06/2017	Laundry wall lining	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works