

SITE SPECIFIC Risk Assessment

| Date: | New | ✓ | Revised | Page | |
|-------|-----|---|---------|------|---|
| | | | | _ | i |

TRADE: FLOOR SANDER / FINISHER

| Job No: | 7630/15 | Client: | FAGLIONI |
|----------|-------------------------------------|-------------|------------------|
| Address: | 70 Oberon Street, Randwick NSW 2031 | Supervisor: | Jonathon Stewart |

Key: "1" action now "2" action ASAP "3" action ASAP

Note 1: Refer to the general Safety Plan and Safe Work Method Statement.

Note 2: Safe work procedures shall be implemented for the supply and use of a *hazardous chemical / substance/s* on site that complies with the *current material safety data sheet* recommendations and also complies with the requirements of WHS Regulation 2011 Chapter 3 - Part 3.2

Note 3: All *manual tasks* are to comply with the requirements of Safe Work Australia – National Code of Practice for Manual Handling 2009 [or as amended] and /or WorkCover NSW Code of Practice - Hazardous manual tasks

Note 4: Management of the risk of fall from one level to another must comply with Part 3.1 and the requirements of Part 4.4 Falls Clauses 78-80 of WHS Regulation 2011

Note 5: Review of Control Measures - If there are any tasks that may be included by way of variation to the plans or an alternative approach to the set task, it is a requirement to carry out a "specific Risk Assessment" for the task or tasks.

| | | Lil | keliho | od | Result | | | | | | |
|---|---|--------|----------|----------|--------|----------|-------|----------|--|---------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| Access to site / work areas - Slips, trips, falls and accessibility - Access ways not clearly defined | Slips, trips and falls | | ✓ | | | ✓ | | 3 | Assess travel path and distance to work area Ensure unobstructed access to site and work areas. | Site Supervisor / all 'workers' | |
| Stored materials - Slips, trips, falls and accessibility - Access ways not clearly defined | Slips, trips and falls | | ✓ | | | ✓ | | 2 | Assess travel path and distance to work area Ensure unobstructed access to work areas. Provide and maintain barricades to isolate material and to restrict access. Provide designated waste areas | Site Supervisor / all 'workers' | |
| Manual tasks | Muscle strain - back injuries and cuts Over exertion or repetitive movements | | ✓ | | | ✓ | | 2 | Identify the risks and plan the task in consultation with the 'workers' Use task specific trained 'workers' and team lifting Rotate 'workers' and vary tasks | Contractor / all 'workers' | |
| Exposure to dust/ chemical vapours Hazardous | Dust and chemical vapour inhalation / skin and eye allergies/ irritations. | | ✓ | | | √ | | 2 | Identify the risks and plan the task in consultation with the 'workers' Use appropriate PPE - | Contractor / all 'workers' | |

| | | Lil | kelihood | | Result | | t | > | | | |
|--|--|--------|----------|----------|--------|--------|-------|----------|---|-------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| chemical - Biological - | Respiratory | | | | | | | | disposable dust / chemical | | |
| biological - | problems | | | | | | | | vapour protection. | | |
| | | | | | | | | | Monitor for chemical vapours/ airborne dust/ fibres | | |
| Use of electrical powered plant and equipment - Electricity - Exposure to noise - | Electrical shock or electrocution Hearing loss Sight damage | | √ | | | 1 | | 2 | Identify the risks and plan the task in consultation with the 'workers' RCD installed on mains supply / portable generator Protect power lead from damage - sharp edges / vehicular traffic Use stands and hooks for leads in trafficable areas Guards to plant and equipment fully operational. Use of appropriate PPE. Use task specific trained 'workers' in the use of the | Contractor/ all 'workers' | |
| Carry materials and floor sanding equipment to ground floor work area - Slips, trips, falls and accessibility - Access ways not clearly defined - Manual tasks - | Muscle strain - back injuries and cuts Slips, trips, falls and accessibility | | ✓ | | | ✓ | | 2 | plant and equipment Identify the risks and plan the task in consultation with the 'workers' Assess travel path and distance to work area Ensure unobstructed access to work areas. Use task specific trained 'workers' rotate 'workers' and vary tasks. | Contractor / all 'workers' | |
| Use floor sander in confined space - Exposure to noise - Exposure to dust - Hazardous chemicals - Biological - Manual tasks | Hearing damage Inhalation of dust - respiratory problems Eye and skin irritations/ allergies. Back injuries- muscle strain / sprain. Over exertion or repetitive movements | ✓ | | | ✓ | | | 2 | Identify the risks / hazards and plan the task in consultation with the 'workers' Monitor for airborne dust/ fibres Use sanding equipment with vacuum and dust bag attached. Provide and maintain temporary barricades to isolate and to restrict access to work area Use appropriate PPE. Use task specific trained 'workers' in use of the | Contractor / all 'workers' | |

| | | Lil | keliho | od | | Resu | lt | , | | | |
|---|---|--------|----------|----------|-------|----------|-------|----------|--|-------------------------------|------|
| Job Step / Hazard | Potential Harm | Likely | Possible | Unlikely | Major | Severe | Minor | Priority | Possible Controls | Responsible Person/s | Date |
| | | | | | | | | | equipment | | |
| Oil based coatings and solvents - mixing and clean up - Hazardous chemicals - Biological - Manual tasks | Inhalation of fumes respiratory problems Eye and skin irritations / allergies – sight damage | | ✓ | | | 1 | | 3 | Identify the risks / hazards and plan the task in consultation with the 'workers' Substitute material with safer low to no volatile organic compounds [VOC] and avoid contact with skin and eyes. Monitor air quality for chemical vapours Use task specific trained 'workers'. Use appropriate PPE. | Contractor / all 'workers' | |
| Apply finishes to floor in confined areas - Slips, trips, falls and accessibility - Hazardous chemicals - Biological - Manual tasks | Slips, trips and falls Muscle strain - back injuries and cuts Over exertion or repetitive movements Inhalation of fumes - respiratory problems. Eye and skin irritations/ allergies | | √ | | | ✓ | | 3 | Provide SDS. Identify the risks / hazards and plan the task in consultation with the 'workers' Regularly monitor air quality for chemical vapours Use task specific trained 'workers' in the use of the applied finish Ensure adequate ventilation and lighting. Use of appropriate PPE. Provide SDS | Contractor / all 'workers' | |
| Site clean up on completion of work Manual tasks Exposure to dust - Hazardous chemicals Biological - | Inhalation of dust - respiratory problems. Eye and skin irritations / allergies Personal injuries - cuts and abrasions. | | √ | | | ✓ | | 3 | Place all associated building waste and rubbish in the designated waste area / skip bin Leave site / work area in a clean and tidy condition Remove any temporary barricades if no longer required | Contractor / all 'workers' | |

Company Name:

Signed by:

for and on behalf of: Cape Cod Australia Pty. Limited

ABN: 54 000 605 407

Builder's Licence No.: 5519

Address:

I / We have consulted with Cape Cod Australia Pty. Limited and have mutually agreed on the above procedures. This risk assessment provides details on how I / we will manage my / our work on this Cape Cod

Australia Pty. Limited work site.

Phone:

Email: