

# ASBESTOS REGISTER

**SITE:** 7757 Speed.Howden 9 Watson Avenue, North Wahroonga

**LAST UPDATED:** 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/08/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	2.8 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
04/08/2016	Front porch	Asbestos cement sheet	Non-friable	1 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
04/08/2016	Bathroom	Asbestos cement wall lining	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
04/08/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works