

# ASBESTOS REGISTER

**SITE:** 7750 Rich 29 Clyde Street, Croydon Park

**LAST UPDATED:** 16/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/11/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	1.5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
18/11/2016	Front porch	Asbestos cement soffit lining	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works