

ASBESTOS REGISTER

SITE: 7808 Cooper 13 Irvine Street, Kingsford

LAST UPDATED: 20/11/2017

JOB NUMBER CLIENT ADDRESS

| Date Identified | Location of ACM | Type | Friable / Non-Friable | Quantity | Condition | Assessment / Action |
|-----------------|------------------------------------|-----------------------|-----------------------|----------|---------------------|---|
| 18/01/2017 | Gable end lining | Asbestos cement sheet | Non-friable | Nil | Good/stable Painted | 15 sqm removed 20/11/2017 |
| 18/01/2017 | Laundry external wall lining | Asbestos cement sheet | Non-friable | 5sqm | Good/stable Painted | Remove as part of the contract works |
| 18/01/2017 | Garage gable end above roller door | Asbestos cement sheet | Non-friable | 2.5sqm | Good/stable Painted | Protect the retained ACM from damage during the course of the works |