

# ASBESTOS REGISTER

**SITE:** 7821      McAlister      36 Henrietta Street, Waverley

**LAST UPDATED:** 05/05/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/05/2017	Front verandah soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Good/stable Painted	Remove and dispose of the ACM as part of the contract works
04/05/2017	Roof space	Asbestos cement sheet	Non-friable	0.25 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works