ASBESTOS REGISTER



SITE: 7887 Radley 10 Gwandalan Crescent, Berowra LAST UPDATED: 16/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Туре	Friable / Non-Friable	Quantity	Condition	Assessment / Action
13/10/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	24.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/10/2017	Bathroom wall lining under tiles	Asbestos cement sheet	Non-friable	12 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works