

# ASBESTOS REGISTER

**SITE:** 7784      McNaughton      4 Bryant Street, Padstow

**LAST UPDATED:** 28/03/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/10/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	8.5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
18/10/2016	Bathroom wall lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/10/2016	Laundry wall lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/10/2016	Shower wall lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/10/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works

## ASBESTOS REGISTER

18/10/2016	Shed eave soffits and wall lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
18/10/2016	Garage	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works