

# ASBESTOS REGISTER

**SITE:** 7746 Head 10 Tipper Avenue, Bronte

**LAST UPDATED:** 17/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
07/07/2016	Gable ends	Asbestos cement sheet	Non-friable	5.5sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works
07/07/2016	Laundry	Asbestos cement sheet	Non-friable	1.9sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works
07/07/2016	WC	Asbestos cement sheet	Non-friable	1.9sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works
07/07/2016	Garage (To be demolished to ground level)	Asbestos cement wall cladding	Non-friable	16.4sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works  9 sqm removed 07/03/2017  9 sqm removed 08/03/2017