

ASBESTOS REGISTER

SITE: 7834 Beukes.West 10 College Street, Gladesville

LAST UPDATED: 05/07/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
01/07/2017	Study ceiling lining	Asbestos cement sheet	Non-friable	9 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works