

ASBESTOS REGISTER

SITE: 7734 Harris.Deacon 44 Alfred Street, Bronte

LAST UPDATED: 20/11/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
10/11/2016	Roofing material – rear original section	Asbestos sheet roofing	Non-friable	Nil	Good/stable	30 sqm removed 17/11/2017
01/07/2016	Pitched roof cavity	Malthoid sarking	Non-friable	Unknown	Good/stable	To be removed and disposed of as part of the contract works
01/07/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works