

ASBESTOS REGISTER

SITE: 7765 Jacobson 5 Jacques Street, Kingsford

LAST UPDATED: 27/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
27/07/2016	Pitched rood cavity	Malthoid sarking	Non-friable	Unknown	Good/stable	Remove and dispose of the ACM as part of the contract works
27/07/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works