

# ASBESTOS REGISTER

**SITE:** 7764 Symes 16 Woodland Street, Coogee

**LAST UPDATED:** 15/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
14/03/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	11.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
14/03/2017	Gable soffit cladding	Asbestos cement sheet	Non-friable	3 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
14/03/2017	Outside shower wall lining	Asbestos cement sheet	Non-friable	10 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works