

ASBESTOS REGISTER

SITE: 7754 Gunn 16 Lady Game Drive, Killara

LAST UPDATED: 27/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
03/08/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	2.9 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
03/08/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
03/08/2016	Garage	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works