



BS 476: Part 7: 1997

Method For Classification Of The Surface Spread Of Flame Of Products

WF Report Number

182137 (Issue 2)

Date:

13th May 2009

Test Sponsor:

Eurobond Industries Pvt. Ltd.





Bodycote warringtonfire Report No. 182137 (Issue 2)

BS 476: Part 7: 1997 Method For Classification Of The Surface Spread Of Flame Of Products

Sponsored By

Eurobond Industries Pvt. Ltd.
Boston House
Ground Floor
Suren Road
Chakala
Andheri (E)
Mumbai
400 093
India





CONTENTS	PAGE NO.
TEST DETAILS	4
DESCRIPTION OF TEST SPECIMENS	5
TEST RESULTS	7
SIGNATORIES	8
APPENDIX 1	10
APPENDIX 2	11





Test Details

Purpose of test

To determine the performance of a product when it is subjected to the conditions of the test specified in BS 476: Part 7: 1997, "Fire tests on building materials and structures, method for classification of the surface spread of flame of products". This test was therefore performed in accordance with the procedure specified in BS 476: Part 7: 1997, and this report should be read in conjunction with that British Standard.

Scope of test

BS 476: Part 7: 1997 specifies a method of test for measuring the lateral spread of flame along the surface of a specimen of a product orientated in the vertical position, and a classification system based on the rate and extent of flame spread. It provides data suitable for comparing the performances of essentially flat materials, composites, or assemblies, which are used primarily as the exposed surfaces of walls or ceilings.

Fire test study group/EGOLF

Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and have agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.

Instruction to test

The test was conducted on the 8th April 2009 at the request of Eurobond Industries Pvt. Ltd., the sponsor of the test.

Provision of test specimens

The specimens were supplied by the sponsor of the test. **Bodycote** warringtonfire was not involved in any selection or sampling procedure.

Conditioning of specimens

The specimens for testing to BS 476: Part 6: 1989 together with the specimens for testing to BS 476: Part 7: 1997 were received on the 6th April 2009.

Prior to the tests, all of the specimens were conditioned to constant mass at a temperature of 23 \pm 2°C and a relative humidity of 50 \pm 5%. One specimen from the total sample submitted for test was selected for constant mass verification

Form in which the specimens were tested

Assembly

Specimen mounting

Each specimen was placed over 25mm thick by 20mm wide calcium silicate based spacers positioned around its perimeter and mounted onto a backing board so that a 25mm enclosed air gap was provided between the unexposed face of the specimen and the backing board.

Exposed face

The face coated with the PVDF coating was exposed to the heating conditions of the test.





Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

Adhesive Adhesive Nai App App Fla Pro Ge Core Nai We	me of manufacturer plication thickness plication method me retardant details pduct reference neric type four me of manufacturer eight per unit area fickness	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd." Flame retardant grade LDPE (Low Density Polyethylene) "White" Lite Source Hong Kong Ltd. 3.79kg/m² 3mm				
Adhesive Nai App App Fla Pro Gere Core Nai We	plication thickness plication method me retardant details pduct reference neric type lour me of manufacturer eight per unit area	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd." Flame retardant grade LDPE (Low Density Polyethylene) "White" Lite Source Hong Kong Ltd.				
Adhesive Adhesive Nai App App Fla Pro Gei Core Col Nai	plication thickness plication method me retardant details pduct reference neric type our me of manufacturer	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd." Flame retardant grade LDPE (Low Density Polyethylene) "White" Lite Source Hong Kong Ltd.				
Adhesive Na App App Fla Pro Gere Core	plication thickness plication method me retardant details oduct reference neric type	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd." Flame retardant grade LDPE (Low Density Polyethylene) "White"				
Adhesive Nai App App Fla Pro Ger	plication thickness plication method me retardant details pduct reference neric type	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd." Flame retardant grade LDPE (Low Density Polyethylene)				
Adhesive Na App App Fla Pro	plication thickness plication method me retardant details oduct reference	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below "Lite Source Hong Kong Ltd."				
Adhesive Nai App	plication thickness plication method me retardant details	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating See Note 2 below				
Adhesive Nai Api	plication thickness plication method	information relating to the generic type of the component DuPont 0.07mm Bonding between core and aluminium is through heating				
Adhesive Na	olication thickness	information relating to the generic type of the component DuPont 0.07mm				
Fla Pro Gel		information relating to the generic type of the component DuPont				
Fla Pro Ger	mo of manufacturor	information relating to the generic type of the component				
Fla Pro		information relating to the generic type of the				
Fla Pro	neric type					
Fla	oduct reference	"DUPONT"				
	me retardant details	The aluminium is inherently flame retardant				
ı l Thi	ckness	0.50mm				
vve	eight per unit area	1.36kg/m ²				
Facing —	me of manufacturer	Lite Source Hong Kong Ltd.				
	neric type	Aluminium alloy 1100-H18				
	oduct reference	"Front Aluminium Foil"				
	me retardant details	See Note 2 below				
	ecific gravity	See Note 2 below				
	plication method	Hot roller coating				
, Apj	plication thickness	Between 28 and 32 microns				
face) Ap	plication rate	See Note 1 below				
Coating (test ——	our	"Bright Silver"				
	me of manufacturer	Becker Industrial Coating				
	neric type	PVDF (Polyvinylidene Difluoride)				
Pro	oduct reference	"Kynar 500"				
Weight per unit area of composite		6.5 kg/m ² (stated by sponsor) 6.76kg/m ² (determined by Bodyco warringtonfire)				
		4.13mm (determined by Bodycot warringtonfire)				
Thickness of comp		4mm (stated by sponsor)				
Name of manufact		Eurobond Industries Pvt. Ltd.				
Product reference	of composite	"EUROBOND-FR"				
General description		A composite panel comprising coated aluminium facings adhered to an LDPE core				

Continued on next page





	Product reference	"DUPONT"					
	Generic type	Polymer based film					
		The sponsor was unable to provide further					
		information relating to the generic type of the					
Adhesive		component					
ranesive	Name of manufacturer	DuPont					
	Application thickness	0.07mm					
	Application method	Bonding between core and aluminium is through					
		heating					
	Trade name of flame retardant						
	Product reference	"Back Aluminium Foil"					
	Generic type	Aluminium alloy 1100-H18					
Backing	Name of manufacturer	Lite Source Hong Kong Ltd.					
	Weight per unit area	1.36kg/m ²					
	Thickness	0.50mm					
	Flame retardant details	The aluminium is inherently flame retardant					
	Product reference	"Back Coating"					
	Generic type	Anti corrosive coating / service coating					
		The sponsor was unable to provide further					
		information relating to the generic type of the					
Coating	Nome of monufactures	Component Continu					
(reverse	Name of manufacturer	Becker Industrial Coating					
face)	Colour	"Grey / White" See Note 1 below					
	Application rate Application thickness	Between 6 and 10 microns					
	Application method	Hot roller coating					
	Specific gravity	See Note 1 below					
	Flame retardant details	See Note 1 below					
	Flattle retardant details	The FR LDPE granules are blended together and					
		then auto loaded into another chamber. The					
		moisture is removed from the blended mixture					
		before it is extruded. After extruding the dried					
		mixture, is it then formed into a sheet of the desired					
		thickness with the help of calendaring. The coated					
		aluminium is then adhered to the LDPE sheet with					
Brief descri	ption of manufacturing process	the help of the adhesive film. In the cooling stage					
	process	the composite sheets are cooled and levelled and a					
		protective film is applied. The aluminium composite					
		panel is than marked as per operations for					
		traceability. This includes marking the manufacturing					
		date, batch number etc. The aluminium composite					
		panel is then taken off after trimming and cutting					
		into desired sizes.					

Note 1. The sponsor of the test was unwilling to provide this information.

Note 2. The sponsor of the test was unable to provide this information.





Test Results

Results and observations

The test results for the individual specimens, together with observations made during the test and comments on any difficulties encountered during the test are given in Table 1.

Classification

In accordance with the class definitions given in BS 476: Part 7: 1997, the specimens tested are classified as class 1.

Criteria for classification

If the prefix 'D' or suffix 'R' or 'Y' is included in the classification, this indicates that the results should be treated with caution. An explanation of the reason for the prefix and suffixes is given in Appendix 1, together with the irradiance along the horizontal reference line of the specimen position during the test and the classification limits specified in the Standard.

Applicability of test result

The test results relate only to the behaviour of the test specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.

Attention is drawn to Appendix 2 entitled "Effect of thermal characteristics on the performance of assemblies".

Validity


The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Bodycote warringtonfire**.






Signatories







^{*} For and on behalf of **Bodycote warringtonfire**.

Report Issued: 13th May 2009

This version of the report has been produced from a .pdf format electronic file that has been provided by **Bodycote warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Bodycote warringtonfire**. The original signed paper version of this report, which includes signatures in blue ink, is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible **Bodycote warringtonfire** staff.





Table 1

SPECIMEN No.	1	2	3	4	5	6
Maximum distance travelled at 1.5 minutes (mm)	<50	<50	<50	<50	<50	<50
Distance (mm)	Time to travel to indicated distance (minutes : seconds)					
75 165 190 215 240 265 290 375 455 500 525 600 675 710 750 785 825						
Time to reach maximum distance travelled	1:00	1:00	1:00	1:00	1:00	1:00
Maximum distance travelled in 10 minutes (mm)	<50	<50	<50	<50	<50	<50

Note: Six specimens are usually tested. If the test on any specimen is deemed to be invalid, as defined in the Standard, it is permissible for up to a maximum of nine specimens to be tested in order to obtain the six valid test results.

Observations made during test and comments on any difficulties encountered during the test:

None





Page 10 of 12

Appendix 1

Irradiance along the horizontal reference line of	Distance along reference line from the hotter end of the specimen position (mm)	75	225	375	525	675	825
the specimen position during the test	Irradiance at points specified above (kW/m²)	32.5	21.0	14.5	10.0	7.0	5.0

Note: A tolerance of \pm 0.5 kW/m² is specified on the irradiance measurement

Classification of	
spread of flame	

	Spread of F	lame at 1.5 min	Final Spre	Final Spread of Flame		
Classification	Limit (mm)	Limit for one specimen (mm)	Limit (mm)	Limit for one specimen (mm)		
Class 1 Class 2 Class 3	165 215 265	165 + 25 215 + 25 265 + 25	165 455 710	165 + 25 455 + 45 710 + 75		
Class 4		Exceeding the lim	its for class 3			

Explanation of prefix and suffixes which may be added to the classification

- 1. A suffix R is added to the classification if more than six specimens are required in order to obtain six valid test results (e.g. class 2R).
- 2. A prefix D is added to the classification of any product which does not comply with the surface characteristics specified in the Standard and has therefore been tested in a modified form (e.g. class D3).
- 3. A suffix Y is added to the classification if any softening and/or other behaviour that may affect the flame spread occurs (e.g. class 3Y).

For example, a classification of D3RY could be achieved indicating (a) a modified surface has been used; (b) a class 3 result has been obtained; (c) additional specimens have been used to obtain 6 valid results and; (d) softening and/or other behaviour has occurred which is considered to have affected the test result.





Appendix 2

Effect of thermal characteristics on the performance of specimens

The result of the test in accordance with BS 476: Part 7: 1997 is applicable only to the specimens in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test result. It is important that the specimens which are tested fully represent the product which is supplied and the manner in which it will be used. This may require a product to be tested in a number of different ways to determine the classification which will be achieved in its different methods of use.

A surface coating, for example, may be applied to a selected substrate using a particular method and application rate. The test classification which is achieved for that set of specimens will be applicable only to that situation. If the substrate or method and rate of application in a particular practical situation are different from that which was tested, then it will be necessary to determine the classification which will be achieved for that situation. Similarly, specimens incorporating a wallcovering must be fully representative of the situation which occurs in practice and will normally consist of the wallcovering bonded to a chosen substrate with a chosen adhesive; the test result will only apply to that composite system. The same principle applies to any composite or assembly which is being investigated.

It is sometimes possible to assume a `worst case' situation which will enable a chosen set, or sets, of specimens to be constructed and tested to provide a foundation for the assessment of the probable performance of variations within the system. Similarly, it is sometimes possible to formulate a series of exploratory tests to investigate the effect of variations within a product or system, usually culminating in a series of formal tests to provide the basis for a composite assessment of pre-determined variables. In such cases, however, it is essential that careful planning of the programmes is undertaken by suitably qualified fire safety practitioners.

The following is re-produced from Appendix B of BS 476: Part 7: 1997;

With thin materials or composites, particularly those with a high thermal conductivity, the presence of an air gap and the nature of any underlying construction may significantly affect the ignition performance of the exposed surface. Increasing the thermal capacity of the underlying construction increases the "heat sink" effect and may delay ignition of the exposed surface. Any backing provided to the test specimen and in intimate contact with it, such as the non-combustible spacers, may alter this "heat sink" effect and may be fundamental to the test result itself. The influence of the underlying layers on the performance of the assembly should be understood and care should be taken to ensure that the result obtained on any assembly is relevant to its use in practice.





The following advice is offered on the construction and preparation of test specimens;

- (a) Where the thermal properties of the product are such that no significant heat loss to the underlying layers can occur, e.g. a material or composite greater than approximately 6 mm thick of high thermal capacity and/or low thermal conductivity, then the product should be tested backed only by the backing board.
- (b) Where the product is normally used as a free-standing sheet and the characteristics noted in (a) do not apply, then an air space should be provided at the back of the product by testing over spacers of non-combustible insulation board 20 mm wide and (25 ± 1) mm thick.
- (c) Where the product is to be used over a low density non-combustible substrate and the characteristics noted in (a) do not apply, then the product should be tested in conjunction with that substrate.
- (d) Where the product is to be used over a combustible substrate and the characteristics noted in (a) do not apply, then the product should be tested in conjunction with that substrate.

NOTE: Discussions are taking place in ISO/TC92/SC1 concerning the possible use of a restricted range of reference substrates (mainly non-combustible) where it is not apparent or possible to test materials or products in the representative end-use substrate.







