



AMC		ANNEXURE 1 Preventive Maintenance Report							
Store / Location		Lacoste - 360				Date / Time		19/4/2025	
Completed By		A-Team International				Service Type (M/Q/A)			
#	Check	TASK DESCRIPTION	Frequency (Q)			X	Remarks		
			M	Q	A				
		AHU / FCU No : (Not Applicable)							
1	☒	Check for unusual noise	X	X	X				
2	☒	Switch off & isolate Power	X	X	X				
3	☒	Inspect & Clean Condensate Drain tray and connections	X	X	X				
4	☒	Clean air filter and check their condition, recommend replacements as needed	X	X	X				
5	☒	inspect coil condition, clean as necessary		X	X				
6	☒	Check actuator valve operation	X	X	X				
7	☒	Check Chilled water lines condition and insulation			X				
8	☒	Inspect all trunking, cabling, wiring, insulation, terminal covers & connections	X	X	X				
9	☒	Clean Grills & Diffusers as required			X				
10	☒	Vent air from cooling coils. Report any significant air locking for further investigation		X	X				
11	☒	Restore power supply and run unit	X	X	X				
12	☒	Check thermostat operation	X	X	X				
13	☒	Check starter/VFD operation	X	X	X				
14	☒	Inspect & clean strainers where fitted			X				
15	☒	Check equipment Current	X	X	X				
16	☒	Check equipment Voltage	X	X	X				
17	☒	Check Room temperature	X	X	X				
		Electrical (DB/lights) (Not Applicable)							
1	☐	Check and the clean the DB		X	X				
2	☐	Check and tightening o the loose wire if any		X	X				
3	☐	Check all the breakers for the proper functioning		X	X				
4	☐	Check all the transformers / ballast for sign of overheating		X	X				
5	☐	Check all the wall power socket for proper functioning		X	X				
		Plumbing (Not Applicable)							
1	☐	Check water connection for any leakage		X	X				
2	☐	Check the sink for any leakage		X	X				
3	☐	Check all the plumbing fitting for any leakage		X	X				
		Drain Flushing	one Month	Two Month	client call				
1	☐	Check the Unit Floor drains and Flush							
2	☐	Check the Unit Floor Cleanouts and Flush							
General Notes:									
Technican Sign :				Client Incharge Sign :					
HAWALLY-BLOCK 11-STREET 169-BUILDING 13525-SAAD ARBID JALAWI BUILDING- FLOOR 1ST-OFFICE 1 WEBSITE: WWW.ATEAMKW.COM-EMAIL:CONTACT@ATEAMKW.COM,INFO@ATEAMKW.COM									