

AMC	ANNEXURE 1 Preventive Maintenance Report					 A-TEAM — آي-تيم —	
Store / Location		Souclat 360 mall			Date / Time 15-02-2024		
Completed By		Rahul			Service Type (M/Q/A)		
#	Check	TASK DESCRIPTION AHU / FCU No :	Frequency (Q)			X	Remarks
			M	Q	A		
1	☐	Check for unusual noise	X	X	X		
2	☐	Switch off & isolate Power	X	X	X		
3	☐	Inspect & Clean Condensate Drain tray and connections	X	X	X		
4	☐	Clean air filter and check their condition, recommend replacements as needed	X	X	X		
5	☐	inspect coil condition, clean as necessary		X	X		
6	☐	Check actuator valve operation	X	X	X		
7	☐	Check Chilled water lines condition and insulation			X		
8	☐	Inspect all trunking, cabling, wiring, insulation, terminal covers & connections	X	X	X		
9	☐	Clean Grills & Diffusers as required			X		
10	☐	Vent air from cooling coils. Report any significant air locking for further investigation		X	X		
11	☐	Restore power supply and run unit	X	X	X		
12	☐	Check thermostat operation	X	X	X		
13	☐	Check starter/VFD operation	X	X	X		
14	☐	Inspect & clean strainers where fitted			X		
15	☐	Check equipment Current	X	X	X		
16	☐	Check equipment Voltage	X	X	X		
17	☐	Check Room temperature	X	X	X		
Electrical (DB/lights)							
1	☒	Check and the clean the DB		X	X		
2	☒	Check and tightening o the loose wire if any		X	X		
3	☒	Check all the breakers for the proper functioning		X	X		
4	☒	Check all the transformers / ballast for sign of overheating		X	X		
5	☒	Check all the wall power socket for proper functioning		X	X		
Plumbing							
1	☐	Check water connection for any leakage		X	X		
2	☐	Check the sink for any leakage		X	X		
3	☐	Check all the plumbing fitting for any leakage		X	X		
Drain Flushing (Not Applicable)			one Month	Two Month	client call		
1	☐	Check the Unit Floor drains and Flush					
2	☐	Check the Unit Floor Cleanouts and Flush					
General Notes: Technician Sign : <u>Rahul</u> Client Incharge Sign : <u>A</u>							
المهبولة - قطعة ١ - مبنى ١٩٣٠١ - شارع ١٤٣ - مبنى صالح عبد الغني المطوع دور ١م - مكتب ١٧ Mahboula - Block 1 - Building 19301 - Street 143 - Saleh Abdul-Ghani Al-Mutawa Building - Floor 1m - Office 17							