

AMC	ANNEXURE 1 Preventive Maintenance Report						 A-TEAM — اي تيم —	
Store / Location <u>Prime Gts / 360 Foodhall</u>				Date / Time <u>17/may/2024</u>				
Completed By <u>Ahmed</u>				Service Type (M/Q/A)				
#	Check	TASK DESCRIPTION	Frequency (Q)			X	Remarks	
AHU / FCU No : (Not Applicable)			M	Q	A			
1	☐	Check for unusual noise	X	X	X			
2	☐	Switch off & isolate Power	X	X	X			
3	☐	Inspect & Clean Condensate Drain tray and connections	X	X	X			
4	☐	Clean air filter and check their condition, recommend replacements as needed	X	X	X			
5	☐	inspect coil condition, clean as necessary		X	X			
6	☐	Check actuator valve operation	X	X	X			
7	☐	Check Chilled water lines condition and insulation			X			
8	☐	Inspect all trunking, cabling, wiring, insulation, terminal covers & connections	X	X	X			
9	☐	Clean Grills & Diffusers as required			X			
10	☐	Vent air from cooling coils. Report any significant air locking for further investigation		X	X			
11	☐	Restore power supply and run unit	X	X	X			
12	☐	Check thermostat operation	X	X	X			
13	☐	Check starter/VFD operation	X	X	X			
14	☐	Inspect & clean strainers where fitted			X			
15	☐	Check equipment Current	X	X	X			
16	☐	Check equipement Voltage	X	X	X			
17	☐	Check Room temperature	X	X	X			
Electrical (DB/lights) (Not Applicable)								
1	☐	Check and the clean the DB		X	X			
2	☐	Check and tightening o the loose wire if any		X	X			
3	☐	Check all the breakers for the proper functioning		X	X			
4	☐	Check all the transformers / ballast for sign of overheating		X	X			
5	☐	Check all the wall power socket for proper functioning		X	X			
Plumbing (Not Applicable)								
1	☐	Check water connection for any leakage		X	X			
2	☐	Check the sink for any leakage		X	X			
3	☐	Check all the plumbing fitting for any leakage		X	X			
Drain Flushing			one Month	Two Month	client call			
1	☒	Check the Unit Floor drains and Flush		/				
2	☒	Check the Unit Floor Cleanouts and Flush		/				
General Notes: Technician Sign : <u></u> Client Incharge Sign : _____								
HAWALLY-BLOCK 11-STREET 169-BUILDING 13525-SAAD ARBID JALAWI BUILDING- FLOOR 1ST-OFFICE 1 WEBSITE: WWW.ATEAMKW.COM-EMAIL:CONTACT@ATEAMKW.COM.INFO@ATEAMKW.COM								

 Equipment Notes: pressure machine (cuator)