

AMC	ANNEXURE 1 Preventive Maintenance Report						
Store / Location <u>Polo Ralph Lauren</u>			Date / Time <u>17/02-2024</u>				
Completed By <u>Hamwinkley</u>			Service Type (M/Q/A)				
#	Check	TASK DESCRIPTION	Frequency (Q)			X	Remarks
			M	Q	A		
AHU / FCU No :							
1	☒	Check for unusual noise	X	X	X		
2	☒	Switch off & isolate Power	X	X	X		
3	☒	Inspect & Clean Condensate Drain tray and connections	X	X	X		
4	☒	Clean air filter and check their condition, recommend replacements as needed	X	X	X		
5	☒	inspect coil condition, clean as necessary		X	X		
6	☒	Check actuator valve operation	X	X	X		
7	☒	Check Chilled water lines condition and insulation			X		
8	☒	Inspect all trunking, cabling, wiring, insulation, terminal covers & connections	X	X	X		
9	☒	Clean Grills & Diffusers as required			X		
10	☒	Vent air from cooling coils. Report any significant air locking for further investigation		X	X		
11	☒	Restore power supply and run unit	X	X	X		
12	☒	Check thermostat operation	X	X	X		
13	☒	Check starter/VFD operation	X	X	X		
14	☒	Inspect & clean strainers where fitted			X		
15	☒	Check equipment Current	X	X	X		
16	☒	Check equipment Voltage	X	X	X		
17	☒	Check Room temperature	X	X	X		
Electrical (DB/lights)							
1	☒	Check and the clean the DB		X	X		
2	☒	Check and tightening o the loose wire if any		X	X		
3	☒	Check all the breakers for the proper functioning		X	X		
4	☒	Check all the transformers / ballast for sign of overheating		X	X		
5	☒	Check all the wall power socket for proper functioning		X	X		
Plumbing							
1	☐	Check water connection for any leakage		X	X		
2	☐	Check the sink for any leakage		X	X		
3	☐	Check all the plumbing fitting for any leakage		X	X		
Drain Flushing (Not Applicable)			one	Two	client		
			Month	Month	call		
1	☐	Check the Unit Floor drains and Flush					
2	☐	Check the Unit Floor Cleanouts and Flush					
General Notes: Technician Sign : <u>Hamwinkley</u> Client Incharge Sign : <u>[Signature]</u>							
المهبولة - قطعة ١ - مبنى ١٩٣٠١ - شارع ١٤٣ - مبنى صالح عبد الغني المطوع دور ١م - مكتب ١٧ Mahboula - Block 1 - Building 19301 - Street 143 - Saleh Abdul-Ghani Al-Mutawa Building - Floor 1m - Office 17							