



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Box Hill
Metro Box Hill Station Box Hill
Contract No: P3581

Callouts:

Date of Call: 16-11-2018 20:58:00
Time of Arrival: 16-11-2018 21:37:00
Rectification Time: 16-11-2018 22:45:00
Time of Departure: 16-11-2018 22:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Escalator 1

For Floor(s): ?

Call Description: Down escalator out of order.

Order Number: 659239

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: 2 screws stuck in combplate. Removed obstruction. Reset handrail entry switch. Ran and checked escalator.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x