



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Bayswater

0 Mountain Hwy & Station St Bayswater

Contract No: P3647

Callouts:

Date of Call: 14-12-2018 22:58:00
Time of Arrival: 14-12-2018 23:50:00
Rectification Time: 15-12-2018 1:15:00
Time of Departure: 15-12-2018 2:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 1

For Floor(s): platform

Call Description: Doors opening and closing \r\nAlso making weird noise

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lift roa\r\nadjust ground floor door lock roller position\r\nAdjust ground floor egress cord \r\nTest operation\r\n

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer