

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Gascoigne
879 - 881 Dandenong road Malvern east
Contract No: P3625

Callouts:

Date of Call: 04-12-2018 20:33:00 Time of Arrival: 04-12-2018 21:15:00 Rectification Time: 04-12-2018 22:25:00 Time of Departure: 04-12-2018 22:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): B1

Call Description: reported car loft not running

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 84 lift on B1 doors closed \r\nchecked fault reset run tested ok

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Matt resident