

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Brunswick St 150, Fitzroy
150 Brunswick St Fitzroy
Contract No: P3511

Callouts: 22347

Date of Call: 20-11-2018 11:24:18 Time of Arrival: 20-11-2018 12:18:00 Rectification Time: 20-11-2018 13:04:00 Time of Departure: 20-11-2018 13:08:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 7

Call Description: lift 1 doors are opening very slowly & lift seems to have stopped on level 1

Order Number: 007084

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Vandalism

Work Action (CORRECTION): See Work description

Work Description: Lift had powder of some kind on light sensors causing them to be blocked.

Part Required: 1 x lvl 7 button

Service Technician Report Customer

Marek Torrico