



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Jones Lang LaSalle
401 Collins St Melbourne
Contract No: P3216

Maintenance ID:

Date of Call: 20-10-2018
Time of Arrival: 5:00:00
Time of Departure: 13:30:00

Maintenance Details

Maintenance Description: Routine service
cleaned and removed all rubbish from lift pits 1 and 2.
Removed old car buffer and reinstalled new car buffer and wired in new buffer switch to lift 1.
checked and tested all pit safeties in lift pit 1.
realigned car door to lift 1.
checked and tested all emergency lift phones.

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller and check operation of various parts.	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y
Pit Clean Report	Y	Y	Y
Test Lift Communications	Y	Y	Y

Service Technician

Robert Pelle

Customer Email

corsina.aquilina@ap.jll.com